MODEL SPECIFICATION

B36344M – Mobile Knee Operated Wash Basin with Upstand And



PRODUCT IMAGE

DOCUMENT SCOPE	DOCUMENT REFERENCE	GENERATED ON
Model	B36344M{PSS}	14 Nov 2026

01 Model specification

B36344M Mobile Knee Operated Wash Basin with Upstand, Hands-Free Sanitizer Dispenser and Demand Valve

Demand / Metered Valve: Metered Valve.

02 Technical specifications

PARAMETER	VALUE	UNIT
Demand / Metered Valve	Metered Valve	–

03 Model and supply data

Parent product	B36344 — Mobile Knee-Operated Wash Basin with Sanitiser Dispenser
Typical lead time	10–15 working days
Warranty	12 months

04 Specification notes

Configuration description

Mobile knee-operated wash basin with an upstand and hands-free sanitiser dispenser for handwashing stations that need to be repositioned.

Selected configuration: Demand / Metered Valve: Metered Valve.

Short Form Specification

SPECIFICATION USE
Use this description when specifying this model.

Basterfield B36344M. Mobile knee-operated wash basin with an upstand and hands-free sanitiser dispenser for handwashing stations that need to be repositioned. Selected configuration: Demand / Metered Valve: Metered Valve.

Detailed specification

- Model: B36344M
- Demand / Metered Valve: Metered Valve

05 Frequently asked questions

When should I select the optional thermostatic mixing valve?

Choose this optional extra when hot and cold water need to be mixed into a pre-tempered supply. The knee control switches water flow on or off; it does not mix the supplies or adjust the temperature. The Advanced Ø22mm valve is supplied and priced separately from the basin.

How many thermostatic mixing valves are recommended?

We recommend one Advanced Ø22mm thermostatic mixing valve per single washing station. Select the valve separately when requesting a quotation.

Does knee operation adjust the water temperature?

No. Knee operation controls the water flow only. A demand valve flows while pressed; a metered valve supplies a preset flow period after activation, where that option is available. For mixed warm water, a thermostatic mixing valve blends the hot and cold supplies upstream. A site that already supplies suitably pre-tempered water may not need an additional local mixing valve.

E&OE. Specifications are subject to change without notice.