MODEL SPECIFICATION

B36650(DK-112) – Basin Hand Wash Pedestal Mounted Knee Activated



PRODUCT IMAGE

DOCUMENT SCOPE	DOCUMENT REFERENCE	GENERATED ON
Model	B36650(DK-112){PSS}	13 Nov 2026

01 Model specification

Hand Wash Basin, Pedestal-Mounted, with Hand Sanitiser Dispenser, Knee Activation and Demand Valve, Basterfield Model B36650(DK-112)

02 Technical specifications

PARAMETER	VALUE	UNIT
Demand / Metered Valve	Demand Valve	–
Activation Mechanism	Knee Activated	–

03 Model and supply data

Parent product	B36650 — Pedestal Mounted Wash Hand Basin with Hand Sanitizer Dispenser
Typical lead time	10–15 working days
Warranty	12 months

04 Specification notes

Configuration description

Pedestal-mounted wash hand basin with a hand sanitiser dispenser for combined handwashing and sanitising stations.

Selected configuration: Demand / Metered Valve: Demand Valve; Activation Mechanism: Knee Activated.

Short Form Specification

SPECIFICATION USE
Use this description when specifying this model.

Basterfield B36650(DK-112). Pedestal-mounted wash hand basin with a hand sanitiser dispenser for combined handwashing and sanitising stations. Selected configuration: Demand / Metered Valve: Demand Valve; Activation Mechanism: Knee Activated.

121 Koornhof Road, Meadowdale, Germiston, South Africa, 1614 · hello@basterfield.co.za · basterfield.co.za · +27 87 095 5357

Detailed specification	• Model: B36650(DK-112) • Demand / Metered Valve: Demand Valve • Activation Mechanism: Knee Activated

05 Frequently asked questions

When should I select the optional thermostatic mixing valve?

This option applies to the knee-activated configurations. Choose this optional extra when hot and cold water need to be mixed into a pre-tempered supply. The knee control switches water flow on or off; it does not mix the supplies or adjust the temperature. The Advanced Ø22mm valve is supplied and priced separately from the basin.

How many thermostatic mixing valves are recommended?

We recommend one Advanced Ø22mm thermostatic mixing valve per single washing station. Select the valve separately when requesting a quotation.

Does knee operation adjust the water temperature?

No. Knee operation controls the water flow only. A demand valve flows while pressed; a metered valve supplies a preset flow period after activation, where that option is available. For mixed warm water, a thermostatic mixing valve blends the hot and cold supplies upstream. A site that already supplies suitably pre-tempered water may not need an additional local mixing valve.

E&OE. Specifications are subject to change without notice.